

Basic Specification on Data Center

| ID | Description                       | Singapore       | Hong Kong       |
|----|-----------------------------------|-----------------|-----------------|
| 1  | Dual power source per rack        |                 |                 |
| 2  | Can provide 16A or 32A per rack   |                 |                 |
| 3  | Power Options per rack            | 1.5KW and above | 1.8KW and above |
| 4  | Power trunking below raised floor |                 |                 |
| 5  | Overhead data tray                |                 |                 |
| 6  | Genset minimum N+1 configuration  |                 |                 |
| 7  | UPS minimum N+1 configuration     |                 |                 |

|    |                                    |               |               |
|----|------------------------------------|---------------|---------------|
| 8  | Hot & cold aisle deployment        |               |               |
| 9  | Standard Rack                      | 600 x 1,000mm | 600 x 1,000mm |
| 10 | Internet Exchange                  |               | 900mm         |
| 11 | Presence of multiple Tele provider |               |               |
| 12 | Carrier Neutral                    |               |               |
| 13 | Provide suite of managed services  |               |               |
|    | - Tape management services         |               |               |
|    | - Backup management services       |               |               |



- System management services



- OS management services



- Remote hands services



- Managed security services



- Monitoring services



14

24 x 7 CSC/NOC Support Centre



15

ISO 9001:2000 QMS Certified 4Q2009



